

CORRIGENDUM-2

01-07-2020

Ref: Open Tender CON/NCR/TECH/Power Pack/2020 dated 08.06.2020

CORRIGENDUM-2 to Open Tender CON/NCR/TECH/Power Pack/2020 dated 08.06.2020 is issued as under:

Issued Clarification No 1 to 8 to bidders' queries

CLARIFICATIONS TO BIDDER'S QUERIES

S.N	Tender clause	Bidder's query	CONCOR Clarification
1	<u>CI-2.A (1) of Sec-IV</u> COOLING SYSTEM 1. Heavy duty radiator with fan 2. Cooling water centrifugal pump 3. Coolant Inhibitor	As per the Tender requirement in Fuel system PT fuel pump is given but XXX shall provide inline fuel pump system.	Standard fitment of engine manufacturer shall be accepted.
2	<u>CI-2.A (4) of Sec-IV</u> LUBE OIL SYSTEM 1. Lube oil pump 2. Lube oil filters 3. Super Bypass filters	As per the Tender requirement in Lube oil system Super by pass filter is given but XXX shall provide additional centrifugal lube oil filter.	Standard fitment of engine manufacturer shall be accepted.
3	<u>CI-2.B (1.5) of Sec-IV</u> The panel should be meeting the requirement of IP-67 protection.	DG set panel as per tender Ingress protection (IP-67) considered which shall not comply therefore we shall provide panel with IP-54.	Tender specification shall prevail.
4	<u>CI-2.B (2.3) of Sec-IV</u> Twenty one (21) numbers of Sockets of 32 AMP equivalent to BCH Brand specifications DS – 3, CAT. NO. DS 3B 7A1 BCH.	As per the tender Plug and socket used for interconnecting cable for Refer connector is given BCH Brand specifications DS – 3, CAT.NO. DS 3B 7A1 which are obsolete therefore we shall provide plug and socket as per standard of equivalent make as given in tender.	Tender specification shall prevail.
5	<u>CI-2.A (22.3) of Sec-IV</u> Load trial of each Power pack shall be carried at Inland Container Depot Dadri by connecting 24 loaded reefer containers for 24 hours continuously.	As per tender during installation and commissioning Load trial of each Power pack shall be carried at Inland Container Depot Dadri by connecting 24 loaded reefer containers for 24 hours continuously but diesel shall be in the scope of client for load of 24 hrs.	The supplier has to bear the cost of diesel during load testing of the power packs.
6	<u>CI-2.D of Sec-IV</u> The power packs shall be fabricated in new 20 feet High Cube ISO container which will be in the scope of contractor.	As per tender Fabrication of container-The power packs shall be fabricated in new 20 feet High Cube ISO container so client shall clarify that Does the container need to be with CSC approval plate or just as per ISO dimensions of 20' high cube.	The new container has to be supplied having CSC plate.

S.N	Tender clause	Bidder's query	CONCOR Clarification
7	<p>CI no.2.A</p> <p>DIESEL GENERATOR SET (Two sets in One Power Pack)</p> <p>An engine of Cummins / Caterpillar / Volvo / Kirloskar make.....</p>	<p>Considering the world wide COVID situation and restrictions / delay in imported material, we may face problem in delivering VOLVO PENTA brand engines which we import from Sweden. This may lead to delay in execution of your contract due to inconsistencies in policies and situations.</p> <p>Hence, we hereby request you to incorporate Mahindra brand diesel engine in tender for better competition and assured delivery.</p>	Tender specification shall prevail.
8	<p><u>CI-2.D of Sec-IV</u></p> <p>The power packs shall be fabricated in new 20 feet High Cube ISO container which will be in the scope of contractor.</p>	<p>Most of the 20' HC containers are from China. Considering current political and also due to small quantity requirement (5 nos only), it may not be possible to get new containers from China.</p> <p>Hence, like similar tender floated in 2017, you are requested to accept used container in good condition without ISO plate but meeting standard ISO dimensions so as to fit on train.</p>	Tender specification shall prevail.