

CORRIGENDUM-1

CORRIGENDUM-1 to tender number TENDER NO: CON/AREA-1/TECH/REEFER POWER PACK-15/2022 for Manufacture, Supply and Commissioning of 15 nos. of Reefer Power packs (200KVA-11 nos. & 500KVA-4 nos.) at Inland Container Depot Dadri is issued for:

1.0 Issue Amendment No.-1 to 2 the Tender,

ALL THE TERMS AND CONDITIONS OF THE BID DOCUMENT SHALL REMAIN UNCHANGED

Group General Manager/Tech/Area-1

Amendment 1 to the clause of tender number CON/AREA-1/TECH/REEFER POWER PACK-15/2022 under Corrigendum-1

Amendment No.	Clause and Section of Tender	Amendment
1.	Clause 4.0 of Section- IV	<p>A clause 4.0 will be added in Section-IV of the Tender Document</p> <p>The bidder should provide telematics in each Power Pack should have at least remote access of following parameter:</p> <ol style="list-style-type: none"> 1. Running Hour of Each DG Set /Power Pack. 2. Fuel Consumption of each DG set/Power Pack. 3. Power Pack Location/DG set 4. Temperature of DG Set/Power Pack. 5. Voltage Current of DG set/Power Pack
2.	Clause 5.0 of Section-IV	<p>A clause 5.0 will be added in Section-IV of the Tender Document</p> <p>100 KVAR capacitor bank in each 200 KVA Reefer Power Pack along with suitable automatic Power Factor correction panel.</p>